



Florida Department of Transportation

RON DESANTIS
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

KEVIN J. THIBAUT, P.E.
SECRETARY

January 21, 2020

MATERIALS BULLETIN NO. 20-03
DCE MEMORANDUM NO. 20-03
(FHWA Approved: 1/21/2020)

This Memo has expired

**TO: DISTRICT MATERIALS AND RESEARCH ENGINEERS
DISTRICT CONSTRUCTION ENGINEERS**

FROM: Timothy Ruelke P.E., Director, Office of Materials
Dan L. Hurtado P.E., Director, Office of Construction

DocuSigned by:
Tim Ruelke
E1D0648853409
DocuSigned by:
Dan Hurtado
C42B6FE133D643A...

COPIES: Will Watts, Scott Arnold, Ananth Prasad, Chad Thompson, Patrick Upshaw, Jose Armenteros

SUBJECT: SUWANNEE AMERICAN CEMENT PLANT (CMT40)

The Suwannee American Cement Plant in Sumterville, FL is producing a new cement identified as Type IL. Suwannee American Cement Sumterville (CMT40) has established a target of 13% replacement of clinker cement with limestone. This blended cement has been designated as Type IL (13) indicating 13% limestone has been added and is in compliance with AASHTO M240.

The Type IL cement has been tested by Suwannee American Cement Sumterville (CMT40) and verified by the State Materials Office for chemical and physical properties of the cement. The clinker used to produce the currently produced Type I/II cement will continue to be used to produce the Type IL with no other changes to the blended cement. With the approval of the Type IL cement, the Department will accept the Type IL cement as a substitute in currently approved concrete mix designs containing Type I/II cement from Suwannee American Cement Sumterville (CMT40). Any adjustment of mix design components shall follow the requirements of Materials Manual 9.2 Volume II.

The following exceptions to this bulletin will require the standard concrete mix design approval process:

1. Approved mix designs requiring Surface Resistivity Test values of 29 kOhm-cm.
2. Approved Self-Consolidating Concrete (SCC) mix designs.
3. Approved Flowing Concrete mix designs.

This memorandum does not waive any specification requirements and will be in effect until **January 13, 2021.**

Should you have any questions please contact Jose Armenteros, State Materials Office 352-955-6666, or Pat Carlton, State Materials Office 352-955-6676.

TR/ja