

NOTES:

I. Use clean free draining sand < 5% passing No. 200 sieve for base (4").

4"

- 2. Welded wire fabric shall meet the requirements of ASTM A185.
- 3. Concrete strength at 28 days shall be f'c=3 ksi.
- 4. Outside edges of slab shall be cast against formwork.

SECTION B-B

SHAFT LOCATION

....

- 5. The $\frac{1}{2}$ " thick expansion joint between shaft and slab shall be sealed with a hot poured elastic joint sealer.
- 6. Slabs to be placed around all Poles and Pull Boxes in rural locations. In urban areas or where space is limited slab dimensions may be adjusted as shown in the plans.
- 7. The pull box shown is $l'-3'' \times l'-3''$; others approved under Section 635 of the Standard Specifications may be used.



2006 FDOT Design St


⊿"

CONVENTIONAL L

PULL BOX

LOCATION

2"



	SLAB DETAILS		
	FOR POLE AND PULL	BOX LOC	CATIONS
andards		Last Revision	Sheet No.
		00	3 of 3
LIGHTING		17500	