

TYPE II



TYPE I

D_1 = 5' Std. (Single Panel For Depths 5' or Less).
D_2 = 5' Std. (Additional Panel For Depths > 5').
Curtain To Reach bottom Up To Depths of 10 Feet.
Two (2) Panels To Be Used For Depths Greater Than
10 Feet Unless Special Depth Curtains Are Specifically
Called For In The Plans Or As Determined By The Engineer.



STAKED TURBIDITY BARRIER

NOTICE:
COMPONENTS OF TYPES I AND II MAY BE SIMILAR OR IDENTICAL TO PROPRIETARY DESIGNS. ANY INFRINGEMENT ON THE PROPRIETARY RIGHTS OF THE DESIGNER SHALL BE THE SOLE RESPONSIBILITY OF THE USER. SUBSTITUTIONS FOR TYPES I AND II SHALL BE AS APPROVED BY THE ENGINEER.

FLOATING TURBIDITY BARRIERS

LEGEND

- Pile Locations
- Dredge Or Fill Area
- Mooring Buoy w/Anchor
- Anchor
- Barrier Movement Due To Current Action

Notes:

1. Turbidity barriers are to be used in all permanent bodies of water regardless of water depth.
2. Number and spacing of anchors dependent on current velocities.
3. Deployment of barrier around pile locations may vary to accommodate construction operations.
4. Navigation may require segmenting barrier during construction operations.
5. For additional information see Section 104 of the Standard Specifications.



TURBIDITY BARRIER APPLICATIONS



Note:
Turbidity barriers for flowing streams and tidal creeks may be either floating, or staked types or any combinations of types that will suit site conditions and meet erosion control and water quality requirements. The barrier types(s) will be at the Contractor's option unless otherwise specified in the plans, however payment will be under the pay items(s) established in the plans for Floating Turbidity Barrier and/or Staked Turbidity Barrier. Posts in staked trubidity barriers to be installed in vertical position unless otherwise directed by the Engineer.

GENERAL NOTES

1. Floating turbidity barriers are to be paid for under the contract unit price for Floating Turbidity Barrier, LF.
2. Staked turbidity barriers are to be paid for under the contract unit price for Staked Turbidity Barrier, LF.

	2008 FDOT Design Standards	Last Revision 07/01/07	Sheet No. 1 of 1
STATE OF FLORIDA DEPARTMENT OF TRANSPORTATION	**TURBIDITY BARRIERS**		Index No. 103