



2008 FDOT Design Standards


Last Revision 07/01/07 1 of 2

DMS GROUNDING DETAILS

Index No. 18305








DETAIL A

DETAIL B



GENERAL NOTES:

- 1. All grounding materials shall meet the requirements of Section A620 of the current Minimum Specifications For Traffic Control Signal Devices (MSTCSD), except as noted.
- 2. All ground rod resistance readings shall be performed as per Standard Specification 785-2.3.4. Submit data sheets to the Engineer.
- 3. Exothermically weld all connections to ground rods.
- 4. The contractor may, upon approval of the Engineer, install a 30-foot sectional ground rod for instances when conditions will not allow for the installation of the 3 auxillary ground rods.
- 5. Install marker tape directly above all grounding electrodes and conductors.
- 6. All RS-232 coaxial and power cable to the DMS shall be completely concealed.
- 7. Copper flat surfaces shall be bolted, welded, or brazed securely to framework to maintain electrical continuity.
- 8. All air terminals must meet UL-96A.
- 9. Grounding system shall be placed within right of way.
- 10 See Index 18102 for ground rod placement detail.

Not To Scale

