Sign or Sign Cluster 3½" 3½" ⅓" Ø Hole O" (Min.) Centroid 1" Ø Hole (Typ.) ¾" Plate BASE PLATE Bottom of Sign or Sign Cluster - ½" Ø Hole $\frac{9}{16}$ " x 1" Slotted Hole (Typ.) ¾" Plate END PLATE - 1/6" Ø Hole (Typ.) SIGN SUPPORT BRACKET U-BOLT PLATE WASHER

NOTES:

DESIGN SPECIFICATIONS: AASHTO Standard Specifications for Structural Supports for Highway Signs, Luminaires and Traffic Signals as modified by the FDOT Structures Manual.

WIND SPEEDS: See Index 11860 - Wind Speeds by County note.

GEOMETRY: Install signs with bottom edge of the lower sign panel at 7' above the gutter line. Edge of sign panels must not extend beyond the inside face of the top of the traffic railing. Sign posts shall be installed plumb.

APPLICABILITY: Mount only to concrete traffic barriers in locations where ground mounting is not possible. Work this Index in conjunction with Index No. 11860.

SHOP DRAWINGS: Shop drawings are not required.

PAYMENT: Payment for sign support bracket shall be included in the cost of the single post sign.

MATERIALS:

Coatings: All steel and fasteners shall be hot dip galvanized in accordance with Specification Section 962. Sign Support Weldment shall be hot dip galvanized after fabrication. Paint sign support brackets and posts when shown in the plans in accordance with Specification Section 649–4.

Support Posts: ASTM A501 5" NPS Schedule 40 Steel Pipe.

Sign Posts: Aluminum Association Alloy 6061-T6 (ASTM B209, B221 or B308) 5" NPS Schedule 40 Aluminum Pipe.

Steel Plates: ASTM A36 or A709 Grade 36.

Anchor Bolts: ASTM F1554 Grade 55 with a single self-locking hex nut and washers. Install anchor bolts perpendicular to the base plates on back of traffic railing. See Anchor Bolt Notes, Sheet 2 of 2.

Adhesive Bonded Anchors: Fully threaded Anchor Bolts with Type HV Adhesive Bonding Material System in accordance with Specification Section 416 & 937. In lieu of the number of anchors specified to be tested in Specification Section 416-6, field test all adhesive bonded anchors installed per this Design Standard.

U-Bolts: ASTM A449 sized for sign post, with flat washers and locking hex nuts.

Welding: Weld in accordance with American Welding Society Structural Welding Code (Steel), ANSI/AWS D1.1 (current edition). Required weld material is E70XX. Nondestructive testing is not required.

SIGN LIMITATIONS TABLE		
MAX. WIND SPEED (MPH)	MAX. SIGN AREA (SF)	MAX. SIGN CENTROID HEIGHT (DIM. A + DIM. C)
110	30	9'-10"
130	25	9'-7"
150	20	9'-7"

Dim. A = Distance from centerline of the Support Post to the bottom of the sign or sign cluster.

Dim. C = Vertical distance from the bottom of the sign or sign cluster to the Centroid of the sign or sign cluster.


LAST DESCRIPTION:
REVISION 01/01/12



FDOT DESIGN STANDARDS
FY 2012/2013

SINGLE POST BRIDGE MOUNTED SIGN SUPPORT

INDEX SHEET NO. NO. 11870 1



(Bridge Deck shown, Approach Slab and Retaining Wall Similar)

LAST REVISION 01/01/12

DESCRIPTION:

