




LAST REVISION 07/01/12	DESCRIPTION:	 FDOT 2014 DESIGN STANDARDS	FLORIDA-U 72 BEAM - STANDARD DETAILS	INDEX NO. 20272	SHEET NO. 1 of 3
---------------------------	--------------	--	---	---------------------------	----------------------------

C:\projects\standards\structures\current\ready\4release\2014B00K\20272-1of3.dgn
sm970re
7:50:54 PM
6/24/2013

C:\projects\standards\structures\current\ready\4\release\2014\B00K\20272-2of3.dgn
 sm970re
 7:50:56 PM
 6/24/2013




END VIEW AT END DIAPHRAGM




SECTION C-C

- NOTES:
1. Drains shall be placed adjacent to each web at each beam end (four drains per beam). Drain Pipe shall be 2" Nominal Pipe Size, Schedule 80 PVC. Provide removable pipe plugs to prevent concrete entrance during beam casting. Plugs to be removed from the inside after casting. Galvanized screen wire shall cover the end of the pipe and bent down around the sides of the pipe, a minimum of 1" and secured prior to casting.
 2. Concrete face may be sloped with a maximum 1:24 draft to facilitate formwork removal.



TOP VIEW OF SKEWED END DIAPHRAGM AND STIRRUP TRANSITION ZONE (Bars 3D2 Not Shown For Clarity)



TOP VIEW OF END DIAPHRAGM (Bars 3D1 And 3D2 Not Shown For Clarity)



LAST REVISION	07/01/05	DESCRIPTION:	FDOT 2014 DESIGN STANDARDS	FLORIDA-U 72 BEAM - STANDARD DETAILS	INDEX NO. 20272	SHEET NO. 2 of 3
---------------	----------	--------------	---------------------------------------	---	---------------------------	----------------------------

6/24/2013 7:50:59 PM sm970re C:\projects\standards\structures\current\ready\4release\2014\BOOK\20272-3of3.dgn


CONVENTIONAL REINFORCING STEEL BENDING DIAGRAMS

BILL OF REINFORCING STEEL FOR ONE BEAM ONLY


MARK	SIZE	NO. REQD.	LENGTH
A1	6	4	Dim. L - 4"
A2	4	14	Dim. L - 4"
B	5	12	6'-1"
C	4	28	5'-7"
D1	3	228	1'-6"
D2	3	38	4'-6"
E	5	24	7'-3"
F	4	28	6'-9"
G	4	See Table	6'-0"
H	4	See Table	5'-1"
K	5	See Table	10'-0"
L	5	32	19'-6"
M	4	See Table	3'-11"
N	3/8" Ø Strand	2	Dim. L - 3"



TOP VIEW OF INTERMEDIATE DIAPHRAGM




SECTION AT INTERMEDIATE DIAPHRAGM




SECTION D-D


- NOTES:
1. Drains shall be placed adjacent to each web at each intermediate diaphragm (two drains per intermediate diaphragm). Drain Pipe shall be 2" Nominal Pipe Size, Schedule 80 PVC. Provide removable pipe plugs to prevent concrete entrance during beam casting. Plugs to be removed from the inside after casting.
 2. Concrete face may be sloped with a maximum 1:24 draft to facilitate formwork removal.
 3. Intermediate diaphragms must be cast and concrete release strength obtained prior to removing beam from casting bed.




Bars 4F




Bars 5K




Bars 4G




Bars 5L



Bars 4C



Bars 4H



Bars 4M

LAST REVISION 07/01/05

DESCRIPTION:

FDOT 2014 DESIGN STANDARDS

FLORIDA-U 72 BEAM - STANDARD DETAILS

INDEX NO. 20272

SHEET NO. 3 of 3