



*Florida Department of Transportation*

RON DESANTIS  
GOVERNOR

1109 S. Marion Avenue  
Lake City, FL 32025-5874

KEVIN J. THIBAUT, P.E.  
SECRETARY

September 4, 2020

To: Prospective Bidders

Maintenance: Jim Brown, Gaye Lynn Normal, Marty Humphries

**Addendum No.: 2, E20E6, FIN# 43545635220, FCO Contract**  
**Remodel the existing men and women's showers in the Lake City Operations Crew Building, Rebuild/Remodel the existing men and women's restrooms at the Lake City Operations Fuel Facility and build a new Inmate Restroom building on the Lake City Operations Yard, and etc. in Columbia County.**

**Attached is the Revised Plans Sheets. Changes were made based on questions/concerns raised by contractors during their field review.**

**In Response to Bid Questions and Answers:**

**Question: Will the new electrical equipment being installed in the new restrooms at the fuel station be required to meet any explosion proof requirements? If so, what is the class and division that needs to be met.**

**Answer: No, the new electrical equipment being installed in the new restrooms at the fuel station will not be required to meet explosion requirements.**

**Question: If existing electrical equipment is not up to the explosion proof requirements will the contractor be expected to upgrade this equipment to meet the class and division.**

**Answer: No, the existing electrical equipment will not be required to be upgraded.**

**Question: Will the exhaust fans go through the roof?**

**Answer: Yes, the exhaust fans will be required to be piped thru the roof.**

**Question: Sheet 14 indicates that the sewer piping will be installed from the cleanout to the City Sewer Main by FDOT. However, the water service is not shown. Can you please specify who is responsible for taking the water service to the building? If the General Contractor is responsible, please indicate the location we would tap the piping from.**

**Answer: FDOT staff will take the water line to the building the contractor shall stub out the water supply pipe 4' from the building at the rear of the inmate restrooms near the mechanical room.**

**Question: Is there a door and hardware schedule? We will need this information in order to provide an accurate quote for doors, frames and hardware.**

**Answer: Specifications/requirements for doors and hardware are shown on the plan sheets. There is no tabular door and hardware schedule.**

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. The bidder is required to acknowledge the addendum in the space provided on the proposal.

All PROPOSAL HOLDERS must acknowledge receipt of this addendum on the first page of the Bid Proposal in the space provided.

---

Company Name

---

Signature

---

Date

Thank you,  
Jim Brown  
District Contracts Administrator  
Phone: 386-758-3798  
Fax: 386-758-3791