



Florida Department of Transportation

RON DESANTIS
GOVERNOR

1109 S. Marion Avenue
Lake City, FL 32025-5874

JARED W. PERDUE, P.E.
SECRETARY

April 26, 2024

To: Prospective Bidders

Addendum No.: 1, F2029, FIN# 42787137201
Remove 28 existing windows and replace them with 28, 4000 double hung all-weld insulated PPG Solarban 70 tinted glass windows. All work shall be properly installed and caulked, etc. in Putnam County.

In response to Bid Questions and Answers:

Question: Do you have an approximate size for the windows?

Answer: The openings are all 36" High by 72" Wide.

Please sign this addendum and return a signed copy to me to indicate receipt.

Company Name

Signature

Date

Thank you,
Brittany Whiddon
District Contracts Administrator
Phone: 386-758-3798
Fax: 386-758-3791