



Florida Department of Transportation

RON DESANTIS
GOVERNOR

1109 S. Marion Avenue
Lake City, FL 32025-5874

JARED W. PERDUE, P.E.
SECRETARY

March 10, 2025

To: Prospective Bidders

Addendum No.: 4, F2034, FIN# 44997665201

Provide sufficient design, work force, equipment, safety, materials, permitting, and all incidentals necessary to design and build a 44' X 176' Equipment Canopy. All work will be in accordance with this Scope, specifications, local building codes, and contract terms. It will be the Contractors responsibility to acquire and comply with all necessary regulations and guidelines that apply to the design and construction work required to complete the project. Contractor shall obtain all required permits and approvals necessary to complete the work. Copies of all required plans, permits, inspections and certifications are to be delivered to the Department Project Manager before final payment has been made.

The Bid Opening Date has changed from Wednesday, March 12, 2025 at 11:00 a.m. to Thursday, March 20, 2025 at 11:00 a.m. Attached are Revised Bid Documents and the Non-Technical Specifications.

Also, in response to Bid Questions and Answers:

1. What is the eave height of the existing building on the attaching wall?
Answer: Eave Height is 20'.
2. If an 18' clearance is needed on the low eave that will have to be below our portal frames on the sidewall, which will dictate our minimum low eave height
Answer: Please provide a minimum height of 16' on the side.
3. The current plan shown is blurry and it is difficult to tell if columns will be in the way of openings. Is there anyway that we can get a clear image/floor plan of where the structure as well as columns need to go?
Answer: See Attached.

Please sign this addendum and return a signed copy to me to indicate receipt.

Company Name

Signature

Date

Thank you,
Brittany Whiddon
District Contracts Administrator
Phone: 386-758-3798