



Florida Department of Transportation

RON DESANTIS
GOVERNOR

1109 S. Marion Avenue
Lake City, FL 32025-5874

JARED W. PERDUE, P.E.
SECRETARY

May 23, 2025

To: Prospective Bidders

Addendum No.: 1, F2037, FIN# 44997665201
Provide sufficient design, work force, equipment, safety, materials, permitting, and all incidentals necessary to design and build a 44' X 176' Equipment Canopy. All work will be in accordance with this scope, specifications, local building codes, and contract terms. It will be the Contractors responsibility to acquire and comply with all necessary regulations and guidelines that apply to the design and construction work required to complete the project. All work will be in accordance with the Department of Transportation's Construction Plans, the 2023 Florida Building Code, and all applicable laws, rules, and codes shall be followed for this project.

In response to Bid Questions and Answers:

1. Question: Will this be a metal building, similar to the one shown in the image below?

Answer: Yes

2. Question: What is the height that you need for this structure?

Answer: As per the scope: Contactor shall design and construct 44' X 176' Equipment Canopy with a minimum 16' side height designed to connect to existing shop with 20' eaves.

3. Question: Will the building be an enclosed structure or an open-bay design?

Answer: Open Bay

4. Question: Concerning the building's utilities and infrastructure:

Answer: As per the scope: No electrical installation required but you will be required to remove any electrical in the way of building the building.

5. Question: Will the project require basic plumbing and electrical work, including lighting, outlets, fans, and any necessary rough ins?

Answer: No new or additional plumbing and electrical will be required, however, any existing utilities that conflict with this project will need to be protected or replaced if necessary.

6. Question: Is the inclusion of a concrete slab within our scope of work a requirement for this project?

Answer: No, however, modifications to the slab may need to be made to accommodate any footers for the metal building supports.

7. Question: Would you happen to have the plans for the building it is butting up to?

Answer: Plans have been attached.

Please sign this addendum and return a signed copy to me to indicate receipt.

Company Name

Signature

Date

Thank you,
Brittany Whiddon
District Contracts Administrator
Phone: 386-758-3798
Fax: 386-758-3791