



Florida Department of Transportation

RON DESANTIS
GOVERNOR

1109 S. Marion Avenue
Lake City, FL 32025-5874

JARED W. PERDUE, P.E.
SECRETARY

September 22, 2025

To: Prospective Bidders

Addendum No.: 1, F2044, FIN# 42787477201

The Florida Department of Transportation is soliciting bidders to remove existing roofs on two buildings (Warehouse and Shop) at the St. Augustine Maintenance Facility. Provide sufficient workforce, equipment, materials, and etc. in St. Johns County.

In response to Bid Questions and Answers:

- 1. Please confirm the low metal roof is excluded from the scope of work. If included, please provide scope.
Answer: Low metal roof is excluded from the scope of work.
- 2. A coverboard is required when torching over iso. Please confirm 1/8" asphaltic coverboard is acceptable.
Answer: 1/8" asphaltic coverboard is acceptable.
- 3. Please confirm brit white is not required and standard white cap sheet can be used.
Answer: Standard white cap sheet is sufficient.
- 4. Did I not check the drawings or is there no drawings for this project? If I did not, we also need drawings and technical specifications, if available
Answer: There are no plans for the shop and warehouse roofs. Please schedule a site visit with Ian Middlemas to look over the work site.

Please sign this addendum and return a signed copy to me to indicate receipt.

Company Name

Signature

Date

Thank you,
Brittany Whiddon
District Contracts Administrator
Phone: 386-758-3798