



Florida Department of Transportation

RON DESANTIS
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

KEVIN J. THIBAUT
SECRETARY

April 15, 2020

ADDENDUM NO. 9

To: ALL DESIGN BUILD FIRMS

FINANCIAL ITEM NUMBER: 220440-1-52-01, 220440-1-56-01, 220440-1-56-04, 220440-1-56-05, 220440-1-56-06

CONTRACT NUMBER: E3S76

DESCRIPTION: SR 30 (US 98) from Bayshore Rd to Portside Dr, Santa Rosa County

PRICE PROPOSALS TO BE RECEIVED: April 17, 2020

Due to a technical issue with the Bid Question and Answer website on Tuesday, April 14, 2020, the following bid question (# 29749) was unable to be posted. The Department's response is included for your use in preparing bid proposals.

Question: Per Addendum 6 to the RFP, the Design Build Team is to utilize tint or dye in the concrete mix for coloring the sound walls. After contacting every FDOT approved concrete precast facility that does sound walls, they all said they will not make them with tint or dye. Therefore, can the contractor use a Class 5 Applied finish Coating (tinted) for coloring the wall?

Response: The intent of the RFP is to provide a coating system that requires minimal maintenance for the sound walls. The concrete admixture of tint or dye is our preferred method of achieving this goal. We acknowledge there may be slight color variation between elements. If the manufacturer is not willing to provide or the color variation becomes unacceptable, we will accept a stain coating.

Please use this information when preparing your proposal.

All PROPOSAL HOLDERS please acknowledge receipt of the addendum on the Design Build Proposal of form (form no. 375-020-12), in the space provided.

Sincerely,

Ranae Dodson
Professional Services Contract Supervisor

cc: Kerrie Harrell, File

Please sign below to acknowledge receipt of Addendum No. 9.