

September 17, 2018

ADDENDUM NO. 3

To: ALL PLANS AND/OR PROPOSAL HOLDERS

FINANCIAL ITEM NUMBER: 42549475201

CONTRACT NUMBER: E3S22

DESCRIPTION: District Three Milton Operation Chiller Replacement

BIDS TO BE RECEIVED: Thursday, September 20, 2018

If you are a PLANS and/or PROPOSAL HOLDER, this is your authorization to make the following changes to the plans package you now have for the subject project:

Please see Addendum No. 3 attached for clarification concerning this project.

Scope of Services

E3S22 Questions and Answers, Pages 6 through 8

The new chiller will require a 120-volt circuit to it outside. I did not see where one is provided to the existing chiller. If there is not one, how and who is to provide it?

Answer: If 120-volt circuit is required for the new unit and one is not existing, the Owner (FDOT) will provide the needed 120-power.

Please use this revision when preparing your bid.

Please sign this addendum in the space provided and fax back to fax number (850) 330-1494. All PROPOSAL HOLDERS please acknowledge receipt of the addendum on Exhibit "One", Scope of Services, in the space provided.

Sincerely,



Steve Thames
Procurement Contract Manager

Rec'd by: _____

Company: _____

Date: _____

fax to (850) 330-1494

ST: md

Enclosures (1)

c.c. Eric Pettis, Chris Kneiss file