

BID QUESTIONS AND RESPONSES 6

F3Z72 - Build new three story FDOT Operations Center Building with related demo of existing buildings per plans and specifications.

Please find below requested questions/clarifications regarding the above referenced bid. The Department's responses are provided for your use in preparing your bid:

27. What are the dimensions of the light poles and the embedded depth. What are the dimensions of the concrete light pole bases?

Response: The dimensions of the light poles are as follows: 22' height pole, 6" diameter. 30" high AFG concrete base with a 30" diameter and 6' embedded base depth.