

BID QUESTIONS AND RESPONSES 8

F3Z72 - Build new three story FDOT Operations Center Building with related demo of existing buildings per plans and specifications.

Please find below requested questions/clarifications regarding the above referenced bid. The Department's responses are provided for your use in preparing your bid:

Are STC ratings tested required? There is no mention of STC in the Div 08 spec, nor are there any manufacturers listed. Are they just going with some seals/gasketing to help reduce sound transmission? Actual rated/tested openings would very significantly increase costs.

Response: No, STC ratings are not required.