



## Florida Department of Transportation

RON DESANTIS  
GOVERNOR

719 South Woodland Boulevard  
DeLand, FL 32720

KEVIN J. THIBAUT, P.E.  
SECRETARY

### Questions and Answers #1

**Contract No.:** E5L30

**Description:** Leesburg Roof System Replacement

**Date:** February 16, 2021

- 
1. Plan Page AA-502 and throughout, note 7.4 indicates the new roof is to be a standing seam metal roof. However, the technical special provisions document section 07 4113 (Page 20) notes that roof panels are to be aluminum metal panels. Typical standing seam metal roofs are steel or galvalume, please clarify as to the materials allowed for the metal roofing.

**Response:** Provide .032 aluminum standing seam panels. Note: Pac Clad, ATAS, Berridge offer .032 aluminum standing seam panels.
  2. Plan Page AA-502 note 7.5 states to remove and replace wet or damaged cover board throughout, however plan page AA-102 Note A indicates that the existing cover board is to be removed throughout and only the insulation is to be checked for damage and replaced. Please clarify if all the cover board is to be replaced.

**Response:** Remove and replace all cover board. Existing wet/damaged insulation is to be replaced.
  3. Page 27 of FCO Non-Technical Specifications, bolded note indicates “**For all Contract sums exceeding \$200,000, the Contractor shall submit a Contractor’s Experience Questionnaire and Financial Statement (see Section A-1 for definition of “Contract Level”).**” Where can the questionnaire be accessed or is it possible to send a copy, please advise.

**Response:** You would need to order the bidding documents by completing the Order Form located on the following website,  
<https://www.fdot.gov/contracts/d5/fco/fcocontracts.shtm>
  4. Page 9 of FCO Non-Technical Specifications, Section A-12 indicates “**Each Bidder shall complete the Proposal Form indicating the bid prices thereon in the appropriate spaces for the Base Bid and alternates on which bids are being made.)**” Where can the proposal form be accessed or is it possible to send a copy, please advise.

**Response:** You would need to order the bidding documents by completing the Order Form located on the following website,  
<https://www.fdot.gov/contracts/d5/fco/fcocontracts.shtm>

5. Are site visits allowed to verify measurements? Is there a set time we can arrange?

Response: Yes, site visits are allowed. Please coordinate with Ken Druding at 386-956-6161 (cell).