



Florida Department of Transportation

RON DESANTIS
GOVERNOR

719 South Woodland Boulevard
DeLand, FL 32720

KEVIN J. THIBAUT, P.E.
SECRETARY

Questions and Answers #3

Contract No.: E5L30

Description: Leesburg Roof System Replacement

Date: February 17, 2021

1. E5L30-Plans: Page 9, Item 6.2 calls for new 2x PT wood blocking. Are we to remove all of the existing and replace with new or replace as needed?

Response: Remove all the existing and replace with new.

2. E5L30-Plans: Specs call-out painting. Plans do not indicate extent of painting required. What is to be painted?

Response: Refer to Technical Special Provisions, Painting page 26-28.

3. E5L30-Bid Proposal Form: Where does unit cost pricing get entered for insulation replacement?

Response: There are no line items, it is a lump sum bid.