



Florida Department of Transportation

719 South Woodland Boulevard
DeLand, FL 32720-6834

RON DESANTIS
GOVERNOR

JARED W. PERDUE, P.E.
SECRETARY

Bid Questions and Answers

Contract No.: F5005
Financial Project No(s): 450185-1-52-01
Description: Oviedo – ADA Restroom Renovation
Date: December 21, 2023

1. During bathroom renovation are Occupant Sensor Controls being required to be installed in bathrooms?

Answer: To comply with Florida Building Code Energy Conservation section C405.2.1, the answer is yes. It is also written in the Scope of Work under Contractor Responsibilities (d). It states that all work shall meet the existing Florida and local Building Codes.

2. Will contractor or FDOT be responsible for securing permit?

Answer: The contractor is responsible for securing permit.