Florida Department of Transportation

RON DESANTIS
GOVERNOR

1000 NW 111 Avenue
Miami, FL 33172

JARED W. PERDUE, P.E.
SECRETARY

# ADDENDUM NO. 1 (Revised)

DATE: October 05, 2026

TO: PROPOSERS

FROM: Lester Silva
Procurement Officer
District Six

RE:

| | |
|---|---|
| Project No.: | F6016 |
| FIN No.: | 450073-1-52-01 |
| Counties: | Miami-Dade |
| Work Description: | District Six Headquarters Lakeside Building Chiller Replacement Project |

## Questions and Answers F6016

**Question 1:** Is the existing chiller controlled by the EMS and is it functioning at this time?

**Answer:** The existing Chiller was controlled CCN through Carrier and is currently not communicating. New unit was called for remote connectivity (Attachment 1) that can communicate with the existing controllers.

**Question 2:** By whom, independent company or by Carrier?

**Answer:** It was through Carrier.

**Question 3:** Is the extended warranty required or not required?

**Answer:** 2-5 years' extended warranty is required to be included in the price proposal. The 1st year warranty will cover parts and labor. The extended 2nd to 5th year warranty shall cover parts only.

**Question 4:** Is extended warranty required?

**Answer:** Yes.

**All other documents for the subject project remain unchanged.**

Failure to file a Protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.