

F9099 Burns Building Restroom Renovation – Bid Questions and Answers

- The outlander floor tile chosen does not come in a 12x12, It comes 12x24 or 24x24.

Provide 24"x24" Floor tile.

- Need to know which series in Outlander also either Grande, Paloza, or medio series?

Provide Outlander Sterling OU57 Grande Series.

- Do they want Calligo tusk wall tile in the Fluted version or flat version?

Provide Glazed Porcelain Calligo Tusk C441 15"X30" installed horizontally.

- On page AA-901 the pic shows a schluter AHK trim piece at floor to wall location if this is being used need to know the finish wanted on the metal. Is Schluter to be used on all out corners on walls? if so need a profile and finish.

Provide Schluter AHK system with satin anodized aluminum finish continuous at all wall to floor tile transitions and install per manufacturer recommended installation instructions.

- Is the burns BLDG one of the few remaining autonomous buildings that are not under the City of Tallahassee Growth Management umbrella, or will a city permit be required?

No, this project requires a permit from the City of Tallahassee. The documents have already been submitted to the City.