



Bid Questions and Answers Report

Date & Time:

8/29/2018 1:22:59 PM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2712

Project: 432404-1-52-01

Letting Date: 8/29/2018

Localtion: CENTRAL OFFICE

Description: SR 212 (BEACH BLVD)

---

Question: 23130: Could the department please specify the equipment to be included at each power service as well as their characteristics such as Volt/Amp? Posted: 8/22/2018 3:50:38 PM

---

Answer: See FDOT Specification Section 639 Electrical Power Service Assemblies. Also, refer to Power Service Detail on Sheet T-41 and the Latest Edition of JEA's Rules and Regulations for Electric Service. Status: ANSWER PUBLISHED  
Posted: 8/23/2018 10:17:21 AM

---

Question: 23131: Could the department please clarify if any pull box has to be removed? Since there is no pay item, is this ancillary to any other pay item? Posted: 8/22/2018 3:55:49 PM

---

Answer: All existing pull boxes are to be removed; the cost is covered under pay item 635-2-11. Refer to General Note 8 on sheet T-6. Status: ANSWER PUBLISHED  
Posted: 8/23/2018 10:18:29 AM