



Bid Questions and Answers Report

Date & Time:

6/13/2018 9:18:50 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2704

Project: 437616-1-52-01

Letting Date: 6/13/2018

Localtion: CENTRAL OFFICE

Description: SR 111

---

Question: 22452: Polypropylene is only listed as an optional material for a couple sections of pipe on this letting. We have reviewed and confirmed that PP meets min/max cover requirements for multiple sections of pipe per Appendix C of the January 2018 FDOT drainage manual. As such, can PP be used for these sections that meet cover requirements? Posted: 5/30/2018 12:22:17 PM

---

Answer: No. Optional pipe materials for the project are only allowed as shown in the optional materials tabulation sheet in the plans. Status: ANSWER PUBLISHED

Posted: 5/31/2018 10:46:13 AM