



Bid Questions and Answers Report

Date & Time:

6/13/2018 9:15:02 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5621

Project: 436237-1-52-01

Letting Date: 6/13/2018

Localtion: CENTRAL OFFICE

Description: SR 5 (US 1)

Question: 22243: Polypropylene is not listed in the optional materials for round pipe on Suntree Blvd in the current plans. We have reviewed and confirmed that polypropylene will meet min/max cover requirements per FDOT index specifications index 205 for most of the pipe in this location. Since PP is fully approved and meets index 205 for many of these runs, can it be utilized as an optional material on Suntree Blvd? Posted: 5/15/2018 11:43:04 AM

Answer: Reinforced Concrete Pipe (RCP) is required on Suntree Blvd. per Brevard County Standards. Use of Polypropylene will not be approved for Suntree Blvd. Status: ANSWER PUBLISHED
Posted: 5/18/2018 4:53:00 PM