



Bid Questions and Answers Report

Date & Time:

3/28/2018 9:39:21 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5605

Project: 435659-2-52-01

Letting Date: 3/28/2018

Localtion: CENTRAL OFFICE

Description: SR 200

Question: 21397: The Summary of Crash Cushions does not list the applicable width of these crash cushion units. The barrier wall in place appears to be wider than a normal median barrier wall. Please provide the width requirement for these crash cushions. Posted: 3/12/2018 2:39:20 PM

Answer: The maximum hazard width for this barrier is 72 inches. Status: ANSWER PUBLISHED
Posted: 3/16/2018 4:23:24 PM

Question: 21510: what size do the interstate shields need to be? 6'x15' or 8'x20'? Posted: 3/22/2018 9:46:12 AM

Answer: The interstate shield pavement markings should be 6' x 15'. Status: ANSWER PUBLISHED
Posted: 3/22/2018 4:59:35 PM