



Bid Questions and Answers Report

Date & Time: 10/31/2018 1:57:27 PM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2720

Project: 437354-1-52-01

Letting Date: 10/31/2018

Localtion: CENTRAL OFFICE

Description: SR 26 (NEWBERRY RD)

---

Question: 23601: On Plan Sheet 32 there is a reference to "Friable Base Material". I cannot find this item described or specification for anywhere in the current Road & Bridge Specification. Can the Department publish a list of acceptable material or a list of sources. Posted: 10/11/2018 1:29:54 PM

---

Answer: Friable base material referenced on Sheet 32 refers to stabilization material. Status: ANSWER PUBLISHED

Posted: 10/23/2018 1:38:16 PM

---

Question: 23712: In the Standard Plans, Index 521-002 (Sheet 1 of 8), Note 3 specifies Type B Stabilization for the top layer of subgrade. What location does this note refer to? Is note 3 referring to the subgrade directly under the wall footing? Posted: 10/23/2018 1:22:45 PM

---

Answer: See sheet 55 for the locations on the project. Yes. Status: ANSWER PUBLISHED

Posted: 10/26/2018 9:27:17 AM