



Bid Questions and Answers Report

Date & Time: 10/31/2018 8:45:24 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6467

Project: 442897-1-52-01

Letting Date: 10/31/2018

Location: CENTRAL OFFICE

Description: NW 22 AVE

Question:	23746: Will spare bearing pads be required for testing purposes? Can this requirement be waived due to project size & timing?	Posted:	10/24/2018 2:18:55 PM
Answer:	No testing is required. Bearing pads are provided just to match existing condition at expansion joints.	Status:	ANSWER PUBLISHED
		Posted:	10/24/2018 4:18:05 PM
Question:	23747: General Note 6b state, " No in-water work is allowed in this project." Please clarify that this environmental note applies to work under water , and that access to the bridge via boat or float is allowed from the canal to perform the work.	Posted:	10/24/2018 2:19:36 PM
Answer:	This contract doesn't include permits for work from bridges or boats. Should the Contractor choose to work from barges or boats, the Contractor shall be responsible for all applicable permits, including permit from the South Florida Water Management District and coordination with the Coast Guard.	Status:	ANSWER PUBLISHED
		Posted:	10/26/2018 7:03:40 PM
Question:	23748: The plans require a Class IV 5,500 PSI mix be used at the Rotation Restrainer Blocks. Due to extremely small lot size, will bag mixes be allowed on this project?	Posted:	10/24/2018 2:20:08 PM
Answer:	Bag mixes will be allowed on this project (f'c= 5,500 psi). All mixes shall be approved by the Engineer and listed on FDOT Approved Product List: https://fdotwp1.dot.state.fl.us/ApprovedProductList/Specifications?specificationRange=900	Status:	ANSWER PUBLISHED
		Posted:	10/26/2018 10:27:01 AM
Answer:	Bag mixes will be allowed on this project (f'c= 5,000 psi). All mixes shall be approved by the Engineer and listed on FDOT Approved Product List: https://fdotwp1.dot.state.fl.us/ApprovedProductList/Specifications?specificationRange=900	Status:	ANSWER VOIDED
		Posted:	10/25/2018 3:45:07 PM

