



Bid Questions and Answers Report

Date & Time: 4/24/2019 9:40:00 AM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1745

Project: 436979-1-52-01

Letting Date: 4/24/2019

Location: CENTRAL OFFICE

Description: SR 45 (US 41)

Question: 25396: As I was looking thorough the plans, I noticed that we had Bid Item sheets for the Lighting and the Signals, but I cannot find the Bid Item sheet for the ITS, even in the Advertisement it does not show the Quantities for the ITS IT-2 to IT -11. how should we proceed? Posted: 4/2/2019 10:56:48 AM

Answer: A bid item sheet is not needed for the ITS component set. Per the Pay Item Note on Roadway Plan Sheet SQ-1, adjustments of ITS pull boxes and repouring of concrete aprons are to be included as part of Pay Item 522-1. Status: ANSWER PUBLISHED
Posted: 4/10/2019 6:34:07 AM