



Bid Questions and Answers Report

Date & Time:

4/24/2019 9:40:25 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7434

Proposal: T2708

Project: 442169-3-52-01

Letting Date: 4/24/2019

Location: CENTRAL OFFICE

Description: HURRICANE IRMA (74) NASSAU DIS REC OFF STATE/ON FED SYS.

Question: 25678: Please consider adding a pay item for temp critical sheet pile for the installation of the wingwall footing. Posted: 4/18/2019 8:37:06 AM

Answer: The Contract Plans do not include a temporary critical wall. The cost of any non-critical temporary wall(s) required to accommodate the Contractor's means and methods shall be incidental to the Contract. Status: ANSWER PUBLISHED
Posted: 4/19/2019 7:11:14 AM