



Bid Questions and Answers Report

Date & Time: 8/28/2019 9:39:19 AM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1747

Project: 433550-3-52-01

Letting Date: 8/28/2019

Location: CENTRAL OFFICE

Description: SR 45 (US 41/TAMIAMI TRAIL)

Question:	26908: The Signal Pay Item for Pull Box 635-2-11 calls for 71 l only see 63 please clarify.	Posted:	8/8/2019 11:12:06 AM
Answer:	The Signal Plans vs the Tabulation of Quantities are correct as shown in the contract plans. Please prepare your bids accordingly.	Status:	ANSWER PUBLISHED
		Posted:	8/16/2019 1:19:47 PM
Question:	26972: Typical section details state that curb pad type B-12.5 is required for curb and gutter construction where asphalt base is used. Are you requiring B-12.5 curb pad for all curb pad included milled and resurfaced areas?	Posted:	8/14/2019 10:59:56 AM
Answer:	This detail is to be used only within the limits noted in the typical section. All other locations shall be constructed per Standard Specification 520 and an asphalt pad is not required.	Status:	ANSWER PUBLISHED
		Posted:	8/22/2019 3:12:27 PM
Question:	26993: If they are available, please provide the existing bridge plans for the NB bridge Structure 170187	Posted:	8/15/2019 11:19:08 AM
Answer:	The requested information can be accessed at the CPP Online Ordering site.	Status:	ANSWER PUBLISHED
		Posted:	8/20/2019 8:42:15 AM
Question:	27104: Are materials subject to Buy America, Buy AmericaN, and/or AIS (American Iron & Steel)?	Posted:	8/21/2019 10:35:54 AM
Answer:	Yes.	Status:	ANSWER PUBLISHED
		Posted:	8/21/2019 4:36:50 PM

Question: 27105: Under single lane closures in the TTCP it states there are restrictions during certain daytime hours, but in parenthesis reads "Within 600' of Signals". Are there no lane restrictions in areas outside the 600' limits of the signals? Posted: 8/21/2019 12:31:11 PM

Answer: Correct, the lane closure restrictions are limited to within 600-feet of the signals, as noted in the plans. There are no restrictions outside of those limits. Status: ANSWER PUBLISHED
Posted: 8/21/2019 4:41:41 PM