



Bid Questions and Answers Report

Date & Time:

8/28/2019 8:31:10 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3648

Project: 435802-1-52-01

Letting Date: 8/28/2019

Location: CENTRAL OFFICE

Description: CR 65A (JUNIPER CREEK RD)

---

Question: 27120: The project plan set includes Standard Drawing 455-003 EDC Instrumentation for Prestressed Piles. Are Electronic Data Collectors required on this project? If so are they only required in the test piles? Posted: 8/22/2019 9:29:29 AM

---

Answer: Electronic Data Collectors are not required on this project. Standard Drawing 455-003 was inadvertently included. Status: ANSWER PUBLISHED  
Posted: 8/22/2019 2:41:55 PM