



Bid Questions and Answers Report

Date & Time:

2/27/2019 11:07:58 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7532

Proposal: T2732

Project: 210024-5-52-01

Letting Date: 2/27/2019

Location: CENTRAL OFFICE

Description: SR 20

---

Question: 24410: Can the Department provide the full geotech report from Universal Engineering Sciences for the project? Posted: 1/18/2019 7:59:31 AM

---

Answer: The documents have been loaded to CPP Online Ordering. Status: ANSWER PUBLISHED

Posted: 1/22/2019 4:47:51 PM

---

Question: 24656: Can the Department provide pavement cores for the existing asphalt? Posted: 2/4/2019 10:31:21 AM

---

Answer: The document has been loaded to CPP Online Ordering as a zip file. Status: ANSWER PUBLISHED

Posted: 2/8/2019 8:34:43 AM

---

Question: 24657: Can the Department provide the Geotechnical Report for the ponds performed by CSI Geo, Inc.? Posted: 2/4/2019 10:34:19 AM

---

Answer: The document has been uploaded to CPP Online Ordering. Status: ANSWER PUBLISHED

Posted: 2/5/2019 6:50:00 AM

---

Question: 24802: Can the department clarify the thickness of the asphalt curb pad. The detail on Sheet 19 references two different thickness's. Posted: 2/13/2019 1:52:21 PM

---

Answer: The curb on the left matches the cross slope of the pavement and has a thickness of 6", while the curb on the right has the standard 7 1/2" thickness. Please see FDOT Standard Plans 520-001. Status: ANSWER PUBLISHED

Posted: 2/13/2019 3:59:47 PM

---

Question: 24806: Which pay item will be used to reimburse asphalt curb pad depicted on sheet 19 of the the roadway plans. Posted: 2/13/2019 2:35:40 PM

---

Answer: Please see Spec 520-12.1. Status: ANSWER PUBLISHED

Posted: 2/13/2019 4:27:00 PM