



Bid Questions and Answers Report

Date & Time:

2/27/2019 8:38:42 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4498

Project: 436893-1-52-01

Letting Date: 2/27/2019

Localtion: CENTRAL OFFICE

Description: CONGRESS AVE

Question: 24796: On sheet 33, Section C-C (Partial Coping Removal), shows a junction slab and coping to be replaced with pedestal. Please advise what pay item this work should go in. Posted: 2/13/2019 9:50:37 AM

Answer: Sheet SQ-8 shows 90 LF (10 ft for each location) of 0521 5 36 barrier wall/ railing (For MSE wall , with Junction Slab). There is also a note in the plan that indicates that pay item 0521 5 36 includes the cost of light pole pedestals. Status: ANSWER PUBLISHED
Posted: 2/14/2019 8:44:19 AM

Question: 24861: Will Railroad Insurance be required on this project? If so, please provide a specification. Posted: 2/19/2019 2:46:05 PM

Answer: Railroad Insurance is not required on this project. Status: ANSWER PUBLISHED
Posted: 2/20/2019 3:15:15 PM