



Bid Questions and Answers Report

Date & Time:

2/27/2019 8:39:28 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4500

Project: 434359-1-52-01

Letting Date: 2/27/2019

Location: CENTRAL OFFICE

Description: NE 23RD AVE

---

Question: 24740: The 18" pipe bid quantity is 192 lf., there is only 144 lf on the plans?  
There is 48 lf of 24" shown with no bid quantity, please advise? Posted: 2/8/2019 9:07:58 AM

---

Answer: All the drainage pipes were revised from 24" diameters to 18" diameters. The 24" diameter call out on the roadway plans, sheet 12 (NW quadrant) was mistakenly left out. It should have been revised to 18". The bid quantity of 192 LF of 18" pipes is correct. A plan revision will be issued by next week. Status: ANSWER PUBLISHED  
Posted: 2/11/2019 3:23:12 PM

---

Question: 24879: Are there plans for the existing bridge to be removed? Posted: 2/20/2019 2:01:49 PM

---

Answer: Existing bridge plans are not available for this bridge Status: ANSWER PUBLISHED  
Posted: 2/20/2019 3:33:29 PM

---

Question: 24880: Are the existing 10" Water Main and 10" Force Mains attached to the existing bridge or is it subaqueous? It appears that both mains remains in place. If they are attached to the existing bridge how will this be handled during removal of the existing bridge? If they are subaqueous is there an as-built drawing showing location and depths? Posted: 2/20/2019 2:02:45 PM

---

Answer: There are no as-built for all three subaqueous lines (12" WM, 10" WM, 10" FM) . They were located by survey. Status: ANSWER PUBLISHED  
Posted: 2/20/2019 3:54:29 PM

Question:	24881: FPL's OE (13kv) calls to be de-energized for crane operations & pile installations. How long will the lines be de-energized? Is this for an extended period of time and not just daily?	Posted:	2/20/2019 2:03:14 PM
Answer:	The lines can be de-energized for a period of three consecutive 8 hour days. Coordination with FPL is required.	Status:	ANSWER PUBLISHED
		Posted:	2/20/2019 3:53:32 PM
Answer:	See bid question 24882	Status:	ANSWER VOIDED
		Posted:	2/20/2019 3:39:39 PM
Question:	24882: FPL's OE (13kv) appear that they will be in direct physical conflict with pile installations. Has the Department considered this issue and if so how will this be dealt with?	Posted:	2/20/2019 2:03:35 PM
Answer:	Piles 1 and 3 at both end bents are located on either side of the OE (13KV) that is to remain. As noted in notes 1 and 2 of the Construction Notes (sheet B-03), the OE lines can be de-energized for a maximum of three consecutive days (8hr days) given the coordination with FPL (also reflected in the FPL work schedule). The use of a barge is permitted for a maximum of three weeks.	Status:	ANSWER PUBLISHED
		Posted:	2/20/2019 3:34:33 PM
Question:	24883: The Wage Rate Decision Number FL150, found on <a href="https://wdol.gov">https://wdol.gov</a> , is showing that it is for Suwanee County. Is this the correct WRDN or is there another one that should be used for Broward County?  General Decision Number: FL190150 01/04/2019 FL150 State: Florida Construction Type: Highway County: Suwanee County in Florida.	Posted:	2/20/2019 2:19:50 PM
Answer:	Supplemental spec one has the wage rate decision number as FL107  LEGAL REQUIREMENTS AND RESPONSIBILITY TO THE PUBLIC - WAGE RATES FOR FEDERAL-AID PROJECTS. (Rev. 9/1/2017) (FA. 10/31/2017) (01/19), page(s) 10-11, is deleted and the following substituted: LEGAL REQUIREMENTS AND RESPONSIBILITY TO THE PUBLIC - WAGE RATES FOR FEDERAL-AID PROJECTS. (REV 9-1-17) (FA 10-31-17) (1-19)	Status:	ANSWER PUBLISHED
		Posted:	2/20/2019 3:10:54 PM
Question:	24949: The wage rates received in the addendum do not have a rate for "Piledriver". Can you please advise?	Posted:	2/25/2019 11:26:54 AM

---

Answer:	Questions posted to this site before 5:00 P.M. (EST) on the seventh calendar day prior to the bid opening, or tenth day prior to the December bid opening will be responded to by the Department. For Questions posted after these times, an answer cannot be assured.	Status:	ANSWER PUBLISHED
		Posted:	2/26/2019 3:25:04 AM