



Bid Questions and Answers Report

Date & Time:

2/27/2019 8:40:10 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6449

Project: 433455-4-52-01

Letting Date: 2/27/2019

Location: CENTRAL OFFICE

Description: SR 5 (US 1)

---

Question: 24747: Could you identify the location of the temporary curb ramps on Fin No. 437918-1-52-01 project plans? They are noted on the Temporary Traffic Control Plans, but not defined as permanent or temporary. Posted: 2/8/2019 2:16:40 PM

---

Answer: A temporary pedestrian ramp needs to be provided when an existing or proposed one is not available along a pedestrian detour. Locations where temporary ramps are expected are: Phase 2 at SW 23rd Ave and SW 27 Street NE and SE corners (sheet 11) and Phase 4 at SW 22 Ave south of US-1 (Sheet 13). Status: ANSWER PUBLISHED  
Posted: 2/11/2019 3:39:51 PM

---

Question: 24825: could you please provide the geotechnical report? thank you Posted: 2/15/2019 8:38:31 AM

---

Answer: Geotechnical Reports are attached. Status: ANSWER PUBLISHED  
Posted: 2/15/2019 4:27:58 PM

---

Document: 8279381: 433455-4\_Geotechnical Report.pdf

433455-4 - Geotechnical Report

---

Document: 8279382: 437918-1\_Geotechnical Report.pdf

437918-1 - Geotechnical Report