STE OF FLORIDA	Bid Questions and A	Answers Report	Date & Time:	7/31/2019 12:29:40 PM			
	District Address:	t Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830					
Cor The March	District Phone:	(863) 519-2222					
Proposal:	T1763						
Project:	441475-1-52-01						
Letting Date:	7/31/2019						
Localtion:	CENTRAL OFFICE						
Description:	AMERICAN LEGIO	AMERICAN LEGION DR					
Question:	26500: What is the required page 8 of the specifications,	minimum pay rate in dollars as s section 7-16.	tated on Posted:	7/9/2019 5:54:57 PM			
	Thank you						
Answer:	The required minimum pay rates in dollars can be found using the website shown below by searching the Wage Determination number of			ANSWER PUBLISHED			
	"FL141".	5 5	Posted:	7/10/2019 10:27:14 AM			
	https://gcc01.safelinks.protection.outlook.com/? url=https%3A%2F%2Fwdolhome.sam.gov%2F&data=02%7C01%7 CMarshall.Douberley%40dot.state.fl.us%7Ceeddb4a2c30d4c80b53408d 70541c071%7Cdb21de5dbc9c420c8f3f8f08f85b5ada%7C0%7C0%7C 636983652263701726&sdata=TY5MbwoAOarIEpWSMg628UuCd 6jbgjh11cdKb3ULRwA%3D&reserved=0						
Question:	Plan Design Note on Dwg.	8-19 Says 200 Contract Days, Days .Please Clarify which one i		7/24/2019 1:43:10 PM			
Answer:	The answer was supplied in sent out to all prospective bio	revision #1. Revision #1, addend dders on 7/25/2019.		ANSWER PUBLISHED 7/25/2019 2:54:47 PM			
Question:	Identified Areas of Contamir Excavation . There is No Me assume this could be in the Rip Rap & as well as the Pro- get a Number of Days for all	e Specifications Package Talks ation with regards to Embankme ntion of this in the Drawings at a Slope areas for Rubble & Filter F oposed Articulating Matt Area. C Bidders to incorporate in their B which our Work Efforts will be I	nt & ll . can we Point Matt an we also ids for the	7/24/2019 1:58:17 PM			

Answer:	Please see Sheet No. B-4, Contamination Note. 'Summary of Activities Report: Asbestos-Containing Materials and Metals-Based Coatings Assessment' can be found available from the URL address provided on page 15 of the Specifications Package. Contract time extension shall not be granted.		ANSWER PUBLISHED	
			7/26/2019 4:16:27 PM	
Question:	26687: PLEASE EXPLAIN THE STANDARD BID AND TIME BID ON PAGE 5 OF THE BID DOCUMENTS. HOW ARE WE TO BID THIS PROJECT. THANK YOU	Posted:	7/24/2019 4:43:51 PM	
Answer:	For clarification, the Standard Bid and Time bid refers to those proposals that have time bid, e.g. A+B or Lane Rental. For the regular contracts that don't have time bid this portion does not apply. It shows only the bid amount.		ANSWER PUBLISHED	
			7/26/2019 4:19:26 PM	
Question:	26688: In regards to construction vehicles on the bridge. What is the bridges load capacity / restriction for weight.	Posted:	7/24/2019 4:52:50 PM	
Answer:	This bridge is a pedestrian bridge, therefore does not have a current complete load rating. However, a pedestrian bridge load rating indicated sufficient capacity for an H-10 live load vehicle.		ANSWER PUBLISHED	
			7/26/2019 4:18:43 PM	
Question:	26689: There are no permits shown in the link provided under 7-2.1 in the specs. Has the department secured the required permits?	Posted:	7/25/2019 8:29:31 AM	
Answer:	Reminder: For 30 day advertisements: Questions posted to this site before 5:00 P.M. (EST) on the seventh calendar day prior to the bid opening,or tenth calendar day prior to the December bid opening, will be responded to by the Department. For questions posted after these times,an answer cannot be assured. For all questions posted before the deadline, the Department will provide and post responses at the samewebsite before 8:00 A.M. (EST) on the second calendar day prior to bid opening.		ANSWER PUBLISHED	
			7/29/2019 3:25:26 AM	
	For 60 day advertisements: Questions posted to this site before 5:00 P.M. (EST) on the tenth calendar day prior to the bid opening,will be responded to by the Department. For questions posted after this deadline, an answer cannot be assured. For all questions postedbefore the deadline, the Department will provide and post responses at the same website before 8:00 A.M. (EST) on the second calendar day prior to bid opening.			
	Take responsibility to review and be familiar with all questions and responses posted to this website and to make any necessary adjustments in the proposal accordingly			

Question:	26690: As Per Pay Item # 0120-6 , How much of the New Fill 771.100 Cubic Yards will be attributable to the Rip Rap Work verses the Backfill to be placed below the proposed New Deck Slab . Reason for this Question is due to the difference in cost from one Work Effort to the Other . Thank You	Posted:	7/25/2019 8:32:19 AM
Answer:	Reminder: For 30 day advertisements: Questions posted to this site before 5:00 P.M. (EST) on the seventh calendar day prior to the bid		ANSWER PUBLISHED
	opening,or tenth calendar day prior to the December bid opening, will be responded to by the Department. For questions posted after these times,an answer cannot be assured. For all questions posted before the deadline, the Department will provide and post responses at the samewebsite before 8:00 A.M. (EST) on the second calendar day prior to bid opening.	Posted:	7/29/2019 3:25:26 AM
	For 60 day advertisements: Questions posted to this site before 5:00 P.M. (EST) on the tenth calendar day prior to the bid opening,will be responded to by the Department. For questions posted after this deadline, an answer cannot be assured. For all questions postedbefore the deadline, the Department will provide and post responses at the same website before 8:00 A.M. (EST) on the second calendar day prior to bid opening.		
	Take responsibility to review and be familiar with all questions and responses posted to this website and to make any necessary adjustments in the proposal accordingly		