



Bid Questions and Answers Report

Date & Time: 7/31/2019 12:30:46 PM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1765

Project: 436982-1-52-01

Letting Date: 7/31/2019

Location: CENTRAL OFFICE

Description: 51ST ST W

Question: 26683: On the lighting load center are you looking for a complete FDOT Load Center or just a meter can and a disconnect on a P-II Pole to run a couple of street lights. Posted: 7/24/2019 3:30:31 PM

Answer: A load center was identified in the plans to include such components as lightning arrester, photo electric cell, grounding, etc. We acknowledge that the lighting plan is for one circuit with two light poles. A load center shall be of suitable size provided to accommodate lighting needs. Status: ANSWER PUBLISHED
Posted: 7/26/2019 4:17:42 PM