



Bid Questions and Answers Report

Date & Time: 7/31/2019 12:34:20 PM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3721

Project: 431883-5-52-01

Letting Date: 7/31/2019

Localtion: CENTRAL OFFICE

Description: SR 30 (US 98)

---

Question: 26538: Polypropylene is not listed as an optional material on the plans. We have reviewed and confirmed that PP meets min/max cover requirements for some pipe segments per Appendix C of the January 2019 FDOT drainage manual. As such, can PP be used for sections that meet cover requirements? Posted: 7/15/2019 2:26:01 PM

---

Answer: No, the EOR(Engineer of Record) has determined that Polypropylene pipe does not meet requirements. Status: ANSWER PUBLISHED

Posted: 7/19/2019 7:29:17 AM