



Bid Questions and Answers Report

Date & Time:

8/26/2020 8:07:49 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5701

Project: 441365-1-52-01

Letting Date: 8/26/2020

Localtion: CENTRAL OFFICE

Description: SR 436

Question: 30745: Please confirm the thickness of the asphalt curb pad for the project. Also, is the curb pad detail applicable to the type E curb as well as the Valley gutter? Posted: 8/12/2020 5:09:06 PM

Answer: The thickness for the asphalt curb pad shown on Typical Section, Sheet No.5, will be 4" and will also apply to the associated valley gutter. Curb Type E shown on Special Details, Sheet No.14, is over existing base material and will not require a curb pad. Status: ANSWER PUBLISHED
Posted: 8/19/2020 11:07:08 AM