



Bid Questions and Answers Report

Date & Time:

2/26/2020 8:33:23 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4534

Project: 436541-1-52-01

Letting Date: 2/26/2020

Location: CENTRAL OFFICE

Description: ROCK ISLAND RD

---

Question: 28693: Is the fence adjacent to the proposed sidewalk, right side, in the FDOT right of way? It is not shown on the roadway plans. Posted: 2/5/2020 8:48:35 AM

---

Answer: The existing fence along the right side back of proposed sidewalk is not within FDOT's right of way. Status: ANSWER PUBLISHED

Posted: 2/6/2020 7:15:36 AM

---

Question: 28700: Will the concrete curb and gutter, type f, require a curb pad? If so, could you provide the specifications? Posted: 2/5/2020 10:51:51 AM

---

Answer: No curb pad is not required because the plans do not require one. The required density under the curb depends if the contractor is required to excavation for the construction of the curb or required to the place embankment for the construction of the curb. If excavation is required for the construction of the curb, the contractor compacts the foundation material to the surrounding embankment density. No density test is required. Status: ANSWER PUBLISHED

Posted: 2/10/2020 6:16:04 PM

---

Answer: The cost of an asphalt curb pad is included in the price of curb and gutter per specification article 520-12.1 Status: ANSWER VOIDED

Posted: 2/6/2020 7:07:56 AM

---

Question: 28833: What type of Sodding will be placed on the project, Bahia or St Augustine? Posted: 2/17/2020 8:05:50 AM

---

Answer: Bid St. Augustine Status: ANSWER PUBLISHED

Posted: 2/20/2020 4:19:22 PM