



Bid Questions and Answers Report

Date & Time:

1/29/2020 8:48:10 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4541

Project: 436868-1-52-01

Letting Date: 1/29/2020

Localtion: CENTRAL OFFICE

Description: SR 5 (US 1)

Question:	28400: Item 0515-1-2 Sheet 10, Detail A calls for Index 515-070, which is Pipe Guiderail. However, description is given as Ped/Bicycle Picket Railing, which is Index 515-062. Please clarify.	Posted:	1/3/2020 1:27:40 PM
-----------	---	---------	---------------------

Answer:	SHEET 10 DESCRIPTION HAS BEEN REVISED TO DELETE "PED/BICYCLE PCKET RAILING" AND ADDED "PIPE HANDRAIL". PIPE HANDRAIL AS PER PAY ITEM 515-1-2 (SHEET 2) AND INDEX 515-070 (FOR DROP OFFS LESS THAN 60") IS TO BE INSTALLED.	Status:	ANSWER PUBLISHED
		Posted:	1/13/2020 12:37:07 PM