



Bid Questions and Answers Report

Date & Time:

1/29/2020 8:51:11 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6523
Project: 429185-3-52-01
Letting Date: 1/29/2020
Location: CENTRAL OFFICE
Description: SR 9 (NW 27TH AVE)

Question: 28558: As it relates to 18" PP pipe on the optional material tabulation table, sheet 10. There is contradictory information, i.e. from S-03 to S-04 (35' of 18"); PP is allowed on S03, not on S-04. Also, the following structures are listed as allowing PP pipe, but also listed on the set of structures where PP can't be used; S-21, S-22, S-27, S-30. PP meets the minimum cover requirements for the crossings under pavement. Please revise table as needed. Thank you.

Posted: 1/22/2020 8:14:11 AM

Answer: Optional material for 18" round pipe can be either PP, HDPE or PVC only for pipes connecting to drainage structures S29, S30, S39, S40, S44, S45, S46, S62, S63 and S64.

Status: ANSWER PUBLISHED

Posted: 1/22/2020 3:05:20 PM