



Bid Questions and Answers Report

Date & Time: 7/29/2020 9:20:25 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7434

Proposal: T2777

Project: 441262-1-52-01

Letting Date: 7/29/2020

Localtion: CENTRAL OFFICE

Description: SR 26

---

Question: 30408: What are the 1.5" Milling Quantities from station 155+80 to 169+46. Posted: 7/1/2020 10:34:44 AM

---

Answer: The quantity is included in Area ID 60625. The stations of this Area ID should be Sta. 155+79.98 to Sta. 221+18.42. Status: ANSWER PUBLISHED

Posted: 7/2/2020 4:01:42 PM

---

Question: 30409: The 1.5" travel lane resurfacing between station 155+80 and station 221+18 calls for Friction Course, Traffic C, FC-12.5, but I did not see these quantities in the summary of quantities. Is this a misprint? Posted: 7/1/2020 10:40:44 AM

---

Answer: The quantity is included in Area ID 91260. The stationing for this Area ID should be Sta. 155+79.98 to Sta. 221+18.42. Status: ANSWER PUBLISHED

Posted: 7/2/2020 4:02:44 PM