



Bid Questions and Answers Report

Date & Time:

3/25/2020 8:02:27 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4548

Project: 443685-1-52-01

Letting Date: 3/25/2020

Localtion: CENTRAL OFFICE

Description: SR 70/OKEECHOBEE RD

---

Question: 29203: To whom it might concern. Posted: 3/18/2020 12:32:19 PM

Can you please provide the specifications for the prestressed concrete pole type p2 services pole specification, including height, and thickness specifications.

For, the installation of the pole, do they need to be direct burial or they going to have a concrete base.

---

Answer: Concrete Pole Prestressed Type P-II shall follow indexes 639-001 and 641-010. Status: ANSWER PUBLISHED

Posted: 3/18/2020 1:25:05 PM