



Bid Questions and Answers Report

Date & Time:

3/25/2020 8:11:03 AM

District Address: District 7 Construction Office, located at 11201 N McKinley, Tampa, FL 33612

District Phone: (813) 975-6285

Proposal: T7441

Project: 437643-1-52-01

Letting Date: 3/25/2020

Localtion: CENTRAL OFFICE

Description: SR 693 (66TH ST)

---

Question: 29056: Traffic Control Plan Phasing Notes (Sheet 63) and Traffic Control Phasing Plans (Sheets 64-70) indicate median and inside lane closures for Phases 1 -4. Please confirm that the median and inside lanes will be closed for the duration of the Phase and the lane closure restrictions (Note 1) do not apply for the median work.

Posted: 3/4/2020 7:48:34 AM

---

Answer: The lane closure time restrictions do not apply to the inside lane closures and median work, as shown in the phasing details 1-4. Inside lanes may be closed only during work periods and opened to travel when no workers are present.

Status: ANSWER PUBLISHED

Posted: 3/19/2020 4:00:02 PM

---

Question: 29254: Plan sheet T-5 shows a bore "3-runs" at 107 LF going across SR 693. Plans are also showing an additional run of conduit crossing SR 693 but no quantities are shown for that run (the run goes to the cabinet pull box at the SE corner and it is approx 113 LF). Please verify quantities for directional bore.

Posted: 3/19/2020 3:36:41 PM

---

Answer: There is only 1 proposed directional bore under SR 693, with 3 runs, for a quantity of 107 LF.

Status: ANSWER PUBLISHED

Posted: 3/19/2020 4:24:07 PM