



Bid Questions and Answers Report

Date & Time: 5/20/2020 7:53:43 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4544

Project: 439847-1-52-01

Letting Date: 5/20/2020

Location: CENTRAL OFFICE

Description: SR 5 (US 1)

Question: 29615: Item 0515-1-2 call for Aluminum pipe guiderail, which is Index 515-070. But, Sheet 5 of the Roadway Plans, Project 436868-1-52-01, says Ped/Bicycle Picket Railing, which is Index 515-052 or Index 515-062. Please clarify. Posted: 4/23/2020 10:56:59 AM

Answer: Abbreviation on Sheet 5 was incorrectly labeled. Use Pay Item 0515-1-2 Aluminum Pipe Guiderail as shown in the Summary of Pay Items sheet and as shown in the Special Details Sheet 8 Wall Cross Section Detail A that calls for ."42" Aluminum Pipe Handrail (See FDOT Standard Plan Index 515-070 SHT 5)" Status: ANSWER PUBLISHED
Posted: 4/23/2020 11:28:12 AM

Question: 29893: The utility schedule link provided does not contain this project. Could it be provided? Posted: 5/13/2020 11:28:10 AM

Answer: The work schedules for both projects were posted to the FTP site at link below: Status: ANSWER PUBLISHED
Posted: 5/13/2020 12:33:17 PM
<https://ftp.fdot.gov/public/folder/HkSWIK59G0qRNsaJU3xXg/permitsandorutilityworkschedules/district4/FPID%2043984715201%20ETC/Utility%20Work%20Schedules/>
There are 3 utility schedules for 436868 and 1 utility schedule for the Lead Project (439847).

Question: 29894: The soil contamination link provided does not contain this project. Could it be provided? Posted: 5/13/2020 12:08:38 PM

Answer: <https://ftp.fdot.gov/public/folder/HkSWIK59G0qRNsaJU3xXg/permitsandorutilityworkschedules/district4/FPID%2043984715201%20ETC/Contamination/> Status: ANSWER PUBLISHED
Posted: 5/13/2020 2:21:28 PM