



Bid Questions and Answers Report

Date & Time:

5/20/2020 8:05:13 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5675

Project: 439238-1-52-01

Letting Date: 5/20/2020

Localtion: CENTRAL OFFICE

Description: SR 25/500/US 441

---

Question: 29609: On Sheet 86 of the Roadway Plans, Project 439238-1-52-01, is the handrail on a slope? If so, what is the slope? Posted: 4/23/2020 10:22:52 AM

---

Answer: The proposed handrail's slope will match the slope of the proposed sidewalk. Status: ANSWER PUBLISHED

Posted: 4/27/2020 3:22:12 PM

---

Question: 29804: The option Base Groups for the turn lanes (Sheet 12). Is it the departments intent to start turn lane with OBG 13 (< 4') and switch to OBG 09 when it is greater than 4', or is the whole turn lane one OGB, Please clarify. Posted: 5/8/2020 9:56:36 AM

---

Answer: On the Turn Lane And Shoulder Widening Details sheet (Sheet 12), the intent is to place Optional Base Group 9 for the proposed turn lane widening in areas wider than 4' and switch to Optional Base Group 13 - Type B 12.5 wherever the proposed turn lane tapers down to less than 4' wide. Status: ANSWER PUBLISHED

Posted: 5/12/2020 1:33:31 PM

---

Question: 29807: Just want FDOT to clarify all new construct shoulders get OBG 01 without black base? Posted: 5/8/2020 12:44:45 PM

---

Answer: The shoulder widening locations shown on the Turn Lane and Shoulder Widening Details sheet (Sheet 12) are shown as "All Turn Lanes Shoulder Widening with Asphalt Base". Therefore, these locations will use Type B 12.5 (asphalt base). Status: ANSWER PUBLISHED

Posted: 5/12/2020 1:35:52 PM

---

Question: 29854: On plan sheet 145 note for gravity wall states cost of gutter and drains shall be incidental to pay item 400-4-11, but their is no pay item for 400-4-11 please advise. Posted: 5/12/2020 8:46:54 AM

---

Answer: Cost of gutter and drains shall be incidental to Pay Item 400-0-11. Status: ANSWER PUBLISHED  
Posted: 5/12/2020 3:10:26 PM

---

Question: 29887: On the plan sheets it calls for resurfacing driveways per index 330-001 but on SQ-39 it calls for driveway reconstruction. Driveway reconstruction requires new base, driveway resurfacing requires just an overlay can FDOT please clarify what the intent is on the driveway resurfacing is. Posted: 5/13/2020 8:41:37 AM

---

Answer: The intent is to mill and resurface the existing driveways. No new base or base work is anticipated for these driveways. Status: ANSWER PUBLISHED  
Posted: 5/15/2020 10:08:39 AM

---

Question: 29902: On sheet 220 and 225 in the MOT plans it shows a proposed sidewalk/shared used path, just want FDOT to clarify if that is in this contract? Posted: 5/13/2020 4:15:17 PM

---

Answer: There is no shared use path in this project. See roadway plan sheets for limits of sidewalk. Status: ANSWER PUBLISHED  
Posted: 5/15/2020 10:10:35 AM