



Bid Questions and Answers Report

Date & Time: 9/30/2020 8:12:20 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7434

Proposal: T2785

Project: 436157-1-52-01

Letting Date: 9/30/2020

Localtion: CENTRAL OFFICE

Description: SR 25 (US 441)

Question: 31111: Concerning the Geosynthetic Reinforced Foundation Over Soft Soil, Bid Item 0145-2-: For the geosynthetic separator fabric, what is the required value for Wide Width Tensile Strength at ultimate strain, per ASTM D 4595 in both the machine and cross directions? Also, on Sheet 99 of the plans, what Unit of Measure is the A.O.S. value listed in, it just shows 0.0169 with no unit? Posted: 9/21/2020 3:11:33 PM

Answer: AOS is in inches. ASTM D 4595 is an acceptable method for determining tensile strength, and all values are as shown on Sheet 99 of the Plans. Status: ANSWER PUBLISHED
Posted: 9/25/2020 7:20:03 AM