



Bid Questions and Answers Report

Date & Time:

4/29/2021 9:04:02 AM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1797

Project: 440134-1-52-01

Letting Date: 4/28/2021

Location: CENTRAL OFFICE

Description: SR 45

---

Question: 33383: Can contractors propose alternative luminaires, so long as it is listed in the FDOT QPL for conventional cobra head streetlighting? Posted: 4/5/2021 5:33:42 PM

---

Answer: Alternative luminaires will not be permitted due to maintaining agency preference. Status: ANSWER PUBLISHED

Posted: 4/9/2021 9:15:26 AM