



Bid Questions and Answers Report

Date & Time:

4/29/2021 8:21:59 AM

District Address: District 7 Construction Office, located at 11201 N McKinley, Tampa, FL 33612

District Phone: (813) 975-6285

Proposal: T7470

Project: 439698-1-52-01

Letting Date: 4/28/2021

Localtion: CENTRAL OFFICE

Description: CR 486 (FOREST RIDGE BLVD)

---

Question: 33451: Since drainage pipe is being installed across N Camomile Way, W Casurina Place, Pentstemont Ct and W Thistle Place please provide the stab, base and asphalt requirements for restoring these roads once pipe is completed. Also, please advise if payment for this work is incidental to the drainage pipe. Posted: 4/12/2021 11:08:14 AM

---

Answer: The pavement restoration requirements for restoring the local roads will meet Citrus County Transportation System Standards. Refer to Chapter 7, Transportation System Standards, for specifics (1" SP-9.5, 6" limerock base, and 6" stabilized subgrade). The cost of restoring the pavement that is disturbed, solely for the purpose of constructing pipe culvert, will be included in the Contract unit price for the pipe culvert. Status: ANSWER PUBLISHED  
Posted: 4/19/2021 4:43:34 PM

---

Question: 33452: Please provide the geotechnical report with soil borings so we can see the material classifications. Posted: 4/12/2021 11:11:19 AM

---

Answer: The Geotechnical Report document is included with this response. Status: ANSWER PUBLISHED  
Posted: 4/19/2021 4:32:46 PM

---

Document: 11606415: 437639-1\_Tierra Geotechnical Report.pdf

Geotechnical Report