



Bid Questions and Answers Report

Date & Time:

4/29/2021 8:23:30 AM

District Address: District 7 Construction Office, located at 11201 N McKinley, Tampa, FL 33612

District Phone: (813) 975-6285

Proposal: T7474

Project: 445554-1-52-01

Letting Date: 4/28/2021

Localtion: CENTRAL OFFICE

Description: SR 600 (US 92)

---

Question: 33670: Legend on Sheet L-9 Says that Directional bore conduit should have 2-2" HDPE conduits. The call out for pay item 630-2-12 only shows 1 run of conduit throughout the plans. Can you please clarify if we need 1 or 2 runs of 2" conduit for directional bore? Posted: 4/20/2021 9:34:03 PM

---

Answer: Install two (2) HDPE conduits in each run of directional bore. Status: ANSWER PUBLISHED

Posted: 4/22/2021 12:36:45 PM

---

Question: 33677: On sheet L-9 the descriptions for both directional bore and trench conduit say that there's four (4) AWG Conductors inside and that the sizes and quantities are shown on the plans. Going through the plan sheets it seems that they show only 3 conductors and their size (either #6 or #4) and the quantities are adequate for those 3 conductors. Can you please provide size and quantity for the "(1) AWG, THWN-2 INSULATED COPPER GROUND CONDUCTOR (GREEN)" that is mentioned on the legend? Posted: 4/21/2021 8:41:48 AM

---

Answer: Three (3) conductors should be installed in the directional bore and trench conduit as shown on the plan sheets. The notes on Sheet L-9 should read as follows: Status: ANSWER PUBLISHED

Posted: 4/22/2021 11:42:57 AM

TWO - 2" DIRECTIONALLY BORED, UL LISTED, HDPE CONDUITS WITH THREE (3) AWG, THWN-2 CONDUCTORS INSIDE CONDUIT. INCLUDES ONE (1) AWG, THWN-2 INSULATED COPPER GROUND CONDUCTOR (GREEN) INSIDE CONDUIT WITH THE OTHER TWO (2) CONDUCTORS. CONDUCTOR SIZES AND QUANTITIES ARE SHOWN ON PLAN SHEETS.

SIZE 2" SCHEDULE 40 PVC UNDERGROUND CONDUIT BY OPEN TRENCH METHOD WITH THREE (3) AWG, THWN-2 CONDUCTORS INSIDE CONDUIT, INCLUDES ONE (1) AWG, THWN-2 INSULATED COPPER GROUND CONDUCTOR (GREEN) INSIDE CONDUIT THE OTHER TWO (2) CONDUCTORS. CONDUCTOR SIZES AND QUANTITIES ARE SHOWN ON PLAN SHEETS.